Certificate of compliance

Applicant:	**SolarEdge Technologies Ltd.** **1 HaMada Street** **Herzliya 4673335** **Israel**
Product:	**Integrated islanding prevention device between a generator and the public low-voltage grid**
Model:	**SE3K** **SE12,5K** **SE4K** **SE15K** **SE5K** **SE16K** **SE6K** **SE17K** **SE7K** **SE20.1K** **SE8K** **SE25K** **SE9K** **SE27.6K** **SE10K**

Use in accordance with regulations:

Islanding prevention device in accordance with IEC 62116:2008 / IEC 62116:2014 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The islanding prevention device is an integral part of the named inverters.

Applied rules and standards:

IEC 62116:2008 / IEC 62116:2014
Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Certification program:	**NSOP-0032-DEU-ZE-V01**
Report number:	**10TH0222-IEC62116_4**
Certificate number:	**U20-0125**
Date of issue:	**2020-03-10**

Certification body

Holger Schaffer

Certification body of Bureau Veritas Consumer Products Services Germany GmbH Accredited according to DIN EN ISO/IEC 17065

DAkkS Deutsche Akkreditierungsstelle D-ZE-12024-01-00

A partial representation of the certificate requires the written permission of Bureau Veritas Consumer Products Services Germany GmbH