Declaration of Compliance

DECLARATION

Applicant: **SolarEdge Technologies LTD**
1 HaMada Street
4673335 Herzeliya
Israel

Product type: Backup Interface (BI)

Model:	**BI-EU1P**	**BI-EU3P**
Rating:	**AC FROM GRID**	
Supported grid	1 ph L-N-PE	3 ph
AC Input Current	100 A	3x63 A
AC Voltage (Nominal)	**230 Vac**	
AC Output Voltage Range	184-264.5 Vac	184-264.5 Vac
AC Frequency Range	50 / 60 Hz	50 / 60 Hz
	AC TO LOADS	
Nominal AC Current Output	100 A	3x63 A
AC Voltage (Nominal)	230 Vac	230 Vac
AC Output Voltage Range	184-264.5 Vac	184-264.5 Vac
AC Frequency Range	50 / 60 Hz	50 / 60 Hz

A representative test sample of above stated model passed the tests according to:

Standard: IEC 62109-1:2010
EN 62109-1:2010

Report no: 21PP137-02

Declaration no: 23-198-00

Date of issue: 2023-05-08

Kiwa Primara GmbH
Gewerbestraße 28
87600 Kaufbeuren
Germany
Tel. +49 8341 99726-0
primara@kiwa.com
www.kiwa.de

J. Jaime Solis Leon
- Digitally signed | see http://ca.kiwa-deutschland.de for more details -

Javier Jaime Solis Leon

kiwa tested
IEC/EN 62109-1